

This is to certify that the items listed herein conform to the appropriate manufactures and that they have been tested and inspected by the manufacture prior to despatch to us. (As stated below)

Peter Pearson

On behalf of Cablenet Trading Ltd February 2022

## **Compliance Statement**



No. 2022-043

## Data communication cable, Category 5e

## **Product description**

Unscreened cable (U/UTP) characterised up to 100 MHz Horizontal floor wiring cable, 100  $\Omega$  4 twisted pairs Flame retardant, halogen free

Product identification XX5E0007

Generic cabling and cabling components standards - Category 5e cable requirements

ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)

- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-3-1:2013
- TIA-568.2-D:2018

## Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report 12131902-03, DANAK-19/22447 **EC Cabling product ID** 5698

**CS valid until** 1 July 2022

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 26 January 2022

Lindolen Pedera

Lars Lindskov Pedersen Test Manager



and ludio

Dennis Andersen Head of Department

FORCE Technology Venlighedsvej 4 2970 Hørsholm Denmark Tel. +45 43 25 14 00 Jan.forcetechnology.com