

Cablenet Compliance Statement

Data Communication Cable Cat6a

This is to certify that the items listed herein conform to the appropriate manufactures and that they have been tested and inspected by the manufacture prior to despatch to us. (As stated below)



Peter Pearson
On behalf of Cablenet Trading Ltd
February 2022



Compliance Statement

No. 2022-046

Data communication cable, Category 6 A

Product description

Screened cable (U/FTP) characterised up to 500 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs
Flame retardant, halogen free

Product identification

XX6A0001Z

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12131902-06, DANAK-19/22450

EC Cabling product ID


5177

CS valid until

1 July 2022

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 26 January 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

