

## Declaration of Performance

<b>Certificate No:</b> 2018-276 <b>Certificate ID No:</b> 6632	<b>1. Unique identification code of the product type:</b> XX6A0005
---	---

**2. Type, batch or serial number or any other element allowing identification of the construction product as required**

Part number XX6A0005 F/FTP Cat6a 4P 23AWG LSZH on box/reel label and/or printed on cable.

**3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specifications, as foreseen by the manufacturer:**

Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.

**4. Name, registered trade name or registered mark and contact address of the manufacturer as required under article 11(5):**

Maxxam Cabling Solutions, AGP House, 2A Albany Park, Frimley Road, Camberley, Surrey, GU16 7PL, UK

**5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):**

Maxxam Cabling Solutions, AGP House, 2A Albany Park, Frimley Road, Camberley, Surrey, GU16 7PL, UK

**6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:**

System 3 AVCP

**7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:**

Notified body number 0199 performed the determination of product type.

**8. Declared Performance**

Essential Characteristics	Performance	Harmonised Technical Specification
Reaction to Fire	Dca-s1,d2,a1	EN50575:2014+A1:2016
Dangerous Substances	None	

This product has undergone a one-time test performance by FORCE Technology and complies with the requirements for the stated reaction for fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

**Signed for and on behalf of the manufacturer by:**  
 Peter Pearson, Managing Director  
 Date of Issue: 1<sup>st</sup> December 2020

